



Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Use with Aboveground Sprinkler Systems

Malleable Iron Non-Gasketed Fittings Manufactured to
Class 150 / 300 ANSI/ASME B 16.3, ASME B16.14, ASME B16.39,
ISO 49 and EN 10242 Specifications
with a Rated Working Pressure of 300 psi (2070 kPa)

Prepared for:

Tupy SA
Avenida Albano Schmidt 3400
Joinville, Santa Catarina 89227 901
Brazil

Manufactured at:

Tupy SA
Avenida Albano Schmidt 3400
Joinville, Santa Catarina 89227 901
Brazil

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”

Approval Identification: 3056665

Approval Granted: August 4, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group